



Customer Picked up Pickup Date: \_\_\_\_\_

Added to Database

Update Chief for Taxes

### BUILDING PERMIT FORM

## Idyllwild Fire Protection District

PO Box 656  
Idyllwild, CA 92549  
(951) 659-2153

PERMIT #. **340**

Please put this # on the plans Form

Submitted Date \_\_\_\_\_  
 Owner/Project Name \_\_\_\_\_  
 Building Address: \_\_\_\_\_  
 APN \_\_\_\_\_  
 Co Permit No \_\_\_\_\_  
 Site Phone \_\_\_\_\_

Grading  
 Building  
 New Res  
 Res Addition  
 Res Remodel  
 New Commercial  
 Special System  
 Sprinkler  
 Alarm  
 Hood/Duct  
 Other \_\_\_\_\_  
 Tenant Improve

Note: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Contact Name \_\_\_\_\_  
 Contact Address # 0 \_\_\_\_\_  
 Contact Street Name \_\_\_\_\_  
 Contact Phone \_\_\_\_\_  
 Square Footage 0 \_\_\_\_\_

Fee Due or Paid \$0.00  
 Cash  
 Check

Receipt No \_\_\_\_\_ check#: 0

Completed by \_\_\_\_\_

Completed Date \_\_\_\_\_

Fee Item Codes: \_\_\_\_\_

App. Notified Date/Time \_\_\_\_\_

Line Item # 4120 Building Plans

Line Item # 4110 Mitigation \$565

Print Date Friday, March 29, 2019 11:28 AM

Final Inspection Pass Final Date: \_\_\_\_\_

Final by: \_\_\_\_\_ X \_\_\_\_\_

**Please make sure customer leaves two (2) copies of prints!**

IF "FINAL INSPECTION PASS" IS CHECKED ABOVE, THEN ALL ITEMS BELOW ARE IN COMPLIANCE

Please find the following results of the above mentioned inspection:

Per the County of Riverside Wildland – Urban Interface Fire Area Compliance Guidelines the following conditions were met:

- 701A.3.2 Vegetation Clearance- Compliant \_\_\_\_\_
- 704A.1 Roofing – Compliant (non wood / class A materials used). \_\_\_\_\_
- 704A.1.3 Roof Valleys – Compliant \_\_\_\_\_
- 704A.1.5 Roof gutters – Compliant \_\_\_\_\_
- 704A.2 Attic Ventilation – Compliant \_\_\_\_\_
- 704A.3 Exterior walls – Compliant ( all product meets or exceeds SFM standard 12-7A-1) \_\_\_\_\_
- 704A.3.2.2 Exterior glazing and windows (one pane tempered) – Compliant \_\_\_\_\_
- 704A.3.2.3 Exterior door assemblies. – Compliant \_\_\_\_\_
- 704A.4 Decking / Floors – Compliant \_\_\_\_\_
- 704A.4.2.1 Under floor and Appendages Protection – Compliant \_\_\_\_\_
- 704A.4.2.2 Unenclosed floor protection – Compliant. \_\_\_\_\_
- CFC 503.2.3 All weather hard surface driveway. \_\_\_\_\_

NFPA-13D or CRC Title 24 part 2.5 section R313.3.8.2 Final inspection. The following items shall be verified upon completion of the system:

1. Sprinkler are not painted, damaged or otherwise hindered from operation.
2. Where a pump is required to provide water to the system, the pump starts automatically upon system water demand.
3. Pressure-reducing valves, water softeners, water filters or other impairments to water flow that were not part of the original design have not been installed.
4. The sign or valve tag required by Section R313.3.7.1 is installed and the owner's manual for the system is present.